

Zestawienie strat pomieszczeń

Nazwa projektu:				PUNKT SELEKTYWNEJ ZBIÓRKI ODPADÓW KOMUNALNYCH								
Zestawienie strat pomieszczeń												
Numer/Opis				$\Phi_{T,e}$ W	Φ_T W	$\Phi_{V,min}$ W	$\Phi_{V,inf}$ W	$\Phi_{V,su}$ W	$\Phi_{V,m,inf}$ W	Φ_{HL} W	Φ_{RH} W	$\Phi_{HL,obl}$ W
Jedn. bud. 01												
003 / Kuchnia				396	390	680	0	0	0	1070		1070
20,0 °C	9,91 m ²	23,46 m ³										
004 / łazienka				286	307	748	0	0	0	1055		1055
24,0 °C	7,16 m ²	16,95 m ³										
001 / Pokój mieszkalny				327	313	206	0	0	0	519		519
20,0 °C	6,41 m ²	15,18 m ³										
002 / Biuro				447	447	343	0	0	0	790		790
20,0 °C	10,65 m ²	25,24 m ³										
Kondygnacja 0												
34,1 m ² 80,8 m ³				1456		1978	0	0	0		0	
Suma dla budynku												
34 m ² 81 m ³				1456		1978	0	0	0		0	